



MAXIMUM UPLIFT, P1 = 585 lbs  
 MAXIMUM HORIZONTAL, P2 = 170 lbs

- 1) Minimum screw spacing = 9/16"
- 2) Equivalent hold down may be substituted
- 3) This detail does not indicate or imply that the depicted bearing is structurally adequate for the loads shown. Design of bearing is req'd
- 4) Detail applies to USC and USD material.
- 5) Max. Reactions shown are non-concurrent.



METAL FRAMING a division of MITEI®  
 www.AEGISMETALFRAMING.COM  
 14515 N. Outer 40 Drive Suite 110  
 Chesterfield, MO 63017  
 Phone:866/902-3447 Fax:314/434-5234

USC/USD TRUSS TO BEARING  
 CONNECTION  
 RT7 - CFS WALL

DETAIL NO.

CD-CFS-1

CATEGORY

STANDARD DETAILS

DATE

3/3/09